

Confirmation

for the Window Profiles division

This is to confirm that for

company **Schüco PWS GmbH & Co. KG**
Selauerstr. 155 a
06667 Weißenfels
GERMANY

testing of **Resistance to weathering, classification according to climate zone S (severe climate) according to DIN EN 12608: 2003-09, Unplasticized polyvinylchloride (PVC-U) profiles for the fabrication of windows and doors - Classification, requirements and test methods**

for the formulation **SCHÜCO 2009 (III)**

was performed by **SKZ - TeConA GmbH**
Friedrich-Bergius-Ring 22
97076 Würzburg
GERMANY

in the period of **7 April 2009 to 14 January 2010.**

In detail, the following tests regarding weathering resistance were carried out in SKZ test order no. 86265/09-I:

- Impact strength (before and) after artificial weathering
- Colour fastness, visual assessment according to ISO 105-A02
- Colour fastness, colourimetric assessment

Assessment of test results:

The requirements according to DIN EN 12608: 2003-09 concerning resistance to weathering, classification according to climate S (severe climate) are fulfilled.

Würzburg, 2011-11-21
Rs/ste

i. V.



Dr.-Ing. Günter Nawroth



i. A.



Wolfgang Ries